

State of California
Department of Public Health
Water Treatment Device
Certificate Number
09 - 2017

Date Issued: October 23, 2009

Trademark/Model Designation

3MFF100

Replacement Elements

3MFF101

Manufacturer: Cuno Inc.

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts

Organic Contaminants

Benzene

p-Dichlorobenzene

Toxaphene

Inorganic/Radiological Contaminants

Lead

Rated Service Capacity: 6000 gal

Rated Service Flow: 2.5 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.